

# Community Lead Testing Program Round 4 June 15 - October 15, 2009

## Round 4 Testing Results:

All samples lead samples were acceptable and below the Drinking Water Quality Standard for lead of 0.010 mg/L.

(Actual test results ranged from <0.0001 mg/L to 0.0039)

### Legend

- Residential Lead Sampling

Thornhill  
50 samples Taken

Unionville  
48 samples Taken

Markham Village  
50 samples Taken

